

JOHN A. WILSON,
Civil Engineer
JOS. M. WILSON,
Civil Engineer & Archt
FRED. G. THORN,
Architect.
HENRY W. WILSON,
Civil Engineer.
CHARLES G. DARRACH,
Civil & Hydraulic Engineer.
HENRY A. MACOMB,
Architect.

Wilson Brothers & Co.

Civil Engineers and Architects.

No. 435 Chestnut St.
Philadelphia, Pa. Aug. 25th, 1887.

Hon. Daniel M. Fox,

Supt., U. S. Mint, Philada.

Sir:

Enclosed please find Estimates in duplicate to Edge Moor Iron Co. for three Internally Fired Cylindrical Steam Boilers complete, with Feed Pumps, Heater &c., as per their contract dated Feb. 15th, 1887., for \$14,900, being total amount of money due on said contract.

These boilers have been tested by the City Boiler Inspector, who states that they have been subjected to a hydrostatic pressure of 153 pounds to the square inch, and are in a condition to sustain a working pressure of 115 pounds of steam to the square inch. Enclosed please find Certificate of said test.

We have tested the boilers for capacity and economy, and find that they are fully up to the requirements of the contract, a detailed statement of which test will be forwarded to you when we make our final report.

Enclosed also, please find Release Lien to the Edge Moor Iron Co. from parties furnishing material and doing work for the said Edge Moor Iron Co., and required to complete their contract.

Very respectfully,

Wilson Bros & Co.

NARA RG104, Entry 1, Box 147

Wilson Brothers & Co.,
Civil Engineers and Architects.
Philadelphia, Pa.
August 25, 1887

Hon. Daniel M. Fox,
Supt., U.S. Mint, Philada.

Sir:

Enclosed please find Estimate in duplicate to Edge Moor Iron Co. for three Internally Fired Cylindrical Steam Boilers complete, with Feed Pumps, Heater &c., as per their contract dated Feb., 1887, for \$14,900, being total amount of money due on said contract.

These boilers have been tested by the City Boiler Inspector, who states that they have been subjected to a hydrostatic pressure of 153 pounds to the square inch, and are in a condition to sustain a working pressure of 115 pounds of steam to the square inch. Enclosed please find Certificate of said test.

We have tested the boilers for capacity and economy, and find that they are fully up to the requirements of the contract, a detailed statement of which test will be forwarded to you when we make our final report.

Enclosed also, please find Release Liens to the Edge Moor Iron Co. from parties furnishing material and doing work for the said Edge Moor Iron Co., and required to complete their contract.

Very respectfully,
Wilson Bro. & Co.